

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20180252
Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	John DiMauro	Passed	Wednesday, February 27, 2019

Informational:

1 Misc

Contractor Mike Fisher's crew finished the installation of the corrections needed to the public section of the sanitary sewer line.

The crew performed the air pressure test on the line today.

I observed the line hold at 4.1 psi for 7 min and 38 seconds with no drop.

The test passed.

Comments: