

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20170394  
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mike Copeland	Failed	Monday, March 04, 2019

Corrective Action Required:

1	Misc	-NAIL GIRDER TRUSS 9" O.C. -NAIL ALL HOLES IN STRAPS FOR OVERDRILLED TOP PLATES -STRAP FOR PORTAL OPENING BELOW GUEST SUITE NEEDS TO EXTEND TO THE DOUBLE TOP PLATE -ALL DEAD SPACES TO ATTIC AREA AND IN LOWER LEVEL NEED TO BE FIREBLOCKED AND FIRESTOPPED. SEVERAL LOCATIONS, CHECK ALL. -1ST FLOOR, NAIL EXTERIOR CORNER STUDS 12" O.C. -SEAL ALL PENETRATIONS BETWEEN FLOORS  DO NOT INSULATE
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**