

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20184050  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	John DiMauro	Partial	Tuesday, March 05, 2019

Corrective Action Required:

1 Misc

The silt fence along the west side of the property and the diversion berm along the south side appear to be installed according to the plans.

The temporary sediment trap # 2 appears to be installed according to the plans.

There are areas along the east side of the property that need to be corrected. There are low areas that still need self fence installed and the diversion berm needs to be corrected to properly direct flow into the trap.

**Comments:**