

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183237
Address: 4724 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Friday, March 08, 2019

Corrective Action Required:

1	Misc	**PLEASE INSTALL COLUMN SUPPORT FOR THE I BEAM IN BASEMENT BELOW THE FRONT BREAKFAST RM. CHECK ON FINAL **OK TO ROCK
---	------	---

Comments: