

Ryan Weers

Report Email: jeremy.young@cityofks.net

Copy Email: ryan@ronweers.com

Main Number

Lab Report Fax No:

Lab Report Contact 1:

Lab Report Contact 2:

Customer ID No: 8799

Customer PO No:

Collected By: Client

Invoice No: 41459

Ron Weers Construction
 2076 5 Foske Ct.

Bucyrus, KS

Report of Analysis

Laboratory Report ID No:

17217

Project Name: Park Ridge 6th Plat

Item No.	Cat NO	ANALYSIS	COLLECTED	ANALYZED	REPORTING LIMIT	RESULTS
	Line NO	SAMPLE TYPE	SAMPLE SITE NOTES		TEST METHOD	
1	6191	Bacteria, P/A E. Coli	8/28/18	8/28/18	1	ABSENT
	104676		PARK RIDGE DR & AVE D1		SM9223 B	
2	6191	Bacteria, P/A E. Coli	8/28/18	8/28/18	1	ABSENT
	104678		SENECA DEAD END D1		SM9223 B	
3	6191	Bacteria, P/A E. Coli	8/28/18	8/28/18	1	ABSENT
	104680		BLUESTONE DEAD END D1		SM9223 B	
4	6191	Bacteria, P/A E. Coli	8/28/18	8/28/18	1	ABSENT
	104681		BLUESTONE & PARK RIDE D1		SM9223 B	
5	6191	Bacteria, P/A E. Coli	8/28/18	8/28/18	1	ABSENT
	104683		BLUESTONE/SENECA D1		SM9223 B	
6	6191	Bacteria, P/A E. Coli	8/29/18	8/29/18	1	ABSENT
	104685		PARK RIDGE DR & AVE D2		SM9223 B	
7	6191	Bacteria, P/A E. Coli	8/29/18	8/29/18	1	ABSENT
	104687		SENECA DEAD END D2		SM9223 B	
8	6191	Bacteria, P/A E. Coli	8/29/18	8/29/18	1	ABSENT
	104689		BLUESTONE DEAD END D2		SM9223 B	
9	6191	Bacteria, P/A E. Coli	8/29/18	8/29/18	1	ABSENT
	104691		BLUESTONE & PARK RIDE D2		SM9223 B	
10	6191	Bacteria, P/A E. Coli	8/29/18	8/29/18	1	ABSENT
	104693		BLUESTONE/SENECA D2		SM9223 B	

Comments, if present, concern this Lab Work Order:

The reported analytical results relate only to the sample submitted.

This report shall not be reproduced, except in full, without written approval by Blue Valley Laboratories, Inc.

Customer ID: 8799

Report ID: 17217

Date Printed or Reprinted 8/30/18

Item Count = 20 Page 1

Blue Valley Laboratories, Inc.
Report For: Ron Weers Construction

Report of Analysis

Report ID No: **17217**

Item No.	Cat NO	ANALYSIS	COLLECTED	ANALYZED	REPORTING LIMIT	RESULTS
	Line NO	SAMPLE TYPE	SAMPLE SITE NOTES		TEST METHOD	
11	6190	Bacteria, P/A T. Coliform	8/28/18	8/28/18	1	ABSENT
	104675		PARK RIDGE DR & AVE D1		SM9223 B	
12	6190	Bacteria, P/A T. Coliform	8/28/18	8/28/18	1	ABSENT
	104677		SENECA DEAD END D1		SM9223 B	
13	6190	Bacteria, P/A T. Coliform	8/28/18	8/28/18	1	ABSENT
	104679		BLUESTONE DEAD END D1		SM9223 B	
14	6190	Bacteria, P/A T. Coliform	8/28/18	8/28/18	1	ABSENT
	104682		BLUESTONE & PARK RIDE D1		SM9223 B	
15	6190	Bacteria, P/A T. Coliform	8/28/18	8/28/18	1	ABSENT
	104684		BLUESTONE/SENECA D1		SM9223 B	
16	6190	Bacteria, P/A T. Coliform	8/29/18	8/29/18	1	ABSENT
	104686		PARK RIDGE DR & AVE D2		SM9223 B	
17	6190	Bacteria, P/A T. Coliform	8/29/18	8/29/18	1	ABSENT
	104688		SENECA DEAD END D2		SM9223 B	
18	6190	Bacteria, P/A T. Coliform	8/29/18	8/29/18	1	ABSENT
	104690		BLUESTONE DEAD END D2		SM9223 B	
19	6190	Bacteria, P/A T. Coliform	8/29/18	8/29/18	1	ABSENT
	104692		BLUESTONE & PARK RIDE D2		SM9223 B	
20	6190	Bacteria, P/A T. Coliform	8/29/18	8/29/18	1	ABSENT
	104694		BLUESTONE/SENECA D2		SM9223 B	