CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181337

Address: 2424 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Driveway Inspection John DiMauro Partial Friday, March 08, 2019

Corrective Action Required:

1 Misc PRE POUR INSPECTION

There appears to be sufficient compacted aggregate. The forms were out of compliance by 6'ft. The contractor is going to make corrections to bring the driveway approach under 36'ft in compliance.

Comments: