

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183519
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Failed	Friday, March 08, 2019

Corrective Action Required:

1 Misc

IBC SECTION 718.4 DRAFTSTOPPING

THERE SHALL BE A DRAFT STOP TO ISOLATE ATTIC AREAS TO LESS THAN 3000 SQUARE FEET. HAVE DESIGN PROFESSIONAL ADDRESS.

REMOVE TEMP LIGHTING

Comments: