

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182996
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Invert	Joe Starlin	Passed	Monday, March 11, 2019

Informational:
1 Misc 12/19/18 Manhole A-1 through A-5 inverts are good. Existing manhole invert will need some modification.

Informational:
2 Misc Joe Starlin 03/11/2019 8:11 AM The existing manhole invert has been corrected and verified by myself and Steve Robbins.

Comments: