

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182193  
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Mark Harding	Failed	Tuesday, March 12, 2019

Corrective Action Required:

1	Misc	- provide approved plans on site . Panel max wire size is violated at 750 kcmill. Grounds not installed. Lugs not installed. Or tightened. Recall when ready and approved plans are on site.
---	------	---

**Comments:**