

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20190138	Date:	March 12, 2019
Project Title:	MID-CONTINENT PUBLIC LIBRARY EAST	Applicant:	
Location:	2240 SE BLUE PKWY, LEES SUMMIT, MO 64063		NATIONAL FIRE SUPPRESSION 501 SUNSHINE RD KANSAS CITY, KS 66115
Type of Work:			
Occupancy Group:	A-3		
Description:	NEW PUBLIC LIBRARY	Primary:	(913) 321-9208
Construction Type:	Type IIB (Unprotected)		
Map Page:	196K		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

All field testing and acceptance testing will be required to be completed prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.