



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20170397	Date:	March 13, 2019
Project Title:	RESIDENCES AT ECHELON - BUILDING #1	Applicant:	
Location:	3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082	T&C FIRE AND SECURITY SYSTEMS LLC	4267 MILAM RD. BATES CITY, MO 64011
Type of Work:		Primary:	(816) 690-4722
Occupancy Group:	R-2		
Description:	NEW 3 STORY APARTMENT BUILDING		

FDTN PERMIT - PRCOM20181560

*NOT TO BE ISSUED UNTIL FIRE DEPARTMENT RELEASES PERMIT

Construction Type: Type VA (1 hour)
Map Page: 215B

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

4. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Acceptance testing of each individual buildings fire alarm system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.