

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183802
Address: 4528 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Brandon Kalwei	Failed	Thursday, March 14, 2019

Corrective Action Required:

1	Misc	STANDING WATER IN BASEMENT, PIPING NEEDS TO BE VISIBLE FOR INSPECTION. MIDDLE SHOWER NEEDS TO BE VENTED
---	------	---

Comments: