

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20183043	Date:	March 15, 2019
Project Title:	ARCADE ALLEY	Applicant:	
Location:	316 SE DOUGLAS ST, LEES SUMMIT, MO 64063		REDLINE AUTOMATIC FIRE SPRINKLER PROTECTION CO 1111 SW 28TH ST BLUE SPRINGS, MO 64015
Type of Work:			
Occupancy Group:	A-2		
Description:	TENANT FINISH FOR ARCADE WITH FULL SERVICE BAR AND SOME FOOD SERVICE	Primary:	(816) 835-1540

**invite planner to final to verify screening of rooftop
equipment

Construction Type: Type VB (Unprotected)
Map Page: 195G

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

All required field and acceptance testing is required to be completed prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.