## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20181337Address:2424 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John DiMauro	Passed	Friday, March 15, 2019
Corrective Action Required: 1 Misc	PRE POUR INSPECTION		
	There appears to be sufficient compacted aggregate. The forms were out of compliance by 6'ft. The contractor is going to make corrections to bring the driveway approach under 36'ft in compliance.		

Comments: