## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSITE20183804

Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**DE - Water Line - Construction** Ronald Paynter Failed Friday, March 15, 2019

Inspection

Corrective Action Required:

1 Misc No aggregate below pipe, tracer wire laying on aggregate instead of pipe.

Need to dig back up and installed correctly

**Comments:**