

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181337
Address: 2424 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Friday, March 15, 2019

Corrective Action Required:

1	Misc	- exterior items, deck inspection, stairs etc. sod, final grade, water meter. -interior protect basmement floor joist per code. - gfci under suspended slab area not working correctly.
---	------	---

Comments: