

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181747
Address: 2533 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Monday, March 18, 2019

Corrective Action Required:

1	Misc	-Landing at patio steps needs to be either same as the 1st step or 36" -no light switch at basement level. switch for stair lighting needs to be a each level. - check all exterior items, gutters ,paint, splashblocks, final grade, sod.
---	------	--

Comments: