

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182996  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Sanitary Sewer - Mandrel</b>	Joe Starlin	Passed	Tuesday, March 19, 2019

Informational:  
1 Misc Joe Starlin 03/19/2019 7:23 AM The crew ran the mandrel through the sanitary lines that where repaired for sags. Manhole 1 and manhole 4.

**Comments:**