

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20183999  
Address: 101 SW MEADOWBROOK DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Jason McRoy	Failed	Wednesday, March 20, 2019

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | 1. Refer wall in kitchen should be 2-2x10 header. fix or provide provide engineers report. |
|   |      | 2. Fire block at fire place where back wall is open to 2nd fl stud space                   |
|   |      | 3. Fire stop master tub drain  |
|   |      | 4. Fire stop dryer vent  |
|   |      | 5. Install ledger locks or equivalent lag bolts at deck ledger board connection.           |

Comments: