

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20183025  
Address: 1825 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Jason McRoy	Failed	Thursday, March 21, 2019

Corrective Action Required:  
2 Misc FIRE BLOCK 10' WALL IN FOYER ABOVE FRONT BEDROOM DOOR AND HALL BATH DOOR.  
  
INSTALL EGRESS WINDOW WELL AT BACK BEDROOM IN BASEMENT  
  
OK TO INSULATE.

**Comments:**