CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182193

Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

DE - Sidewalk Inspection Ronald Paynter Partial Thursday, March 21,

2019

Informational:

1 Misc Mike from Leo Concrete had questions concerning the walks and ADA ramps.

Had to check with Public Works concerning sidewalk and maintenance of the walk. The walk has to meet LS and ADA specs, but is maintained by the property owner. Since the current walk is out of compliance, Mike is allowed

one panel north of the walk and one panel at the south corner of the property to transition from out of spec to correct slope requirements.

Informational:

2 Misc Mike from Leo Concrete had questions concerning the walks and ADA ramps.

Had to check with Public Works concerning sidewalk and maintenance of the walk. The walk has to meet LS and ADA specs, but is maintained by the property owner. Since the current walk is out of compliance, Mike is allowed

one panel north of the walk and one panel at the south corner of the

property to transition from out of spec to correct slope requirements. Forms were placed and aggregate was compacted for the walk on the south side of

the building. It is ready to pour. Need to find out about opening for

handicapped parking area where it meets with the sidewalk.

Informational:

3 Misc Met with Mike from Leo Concrete for pre inspectation of ADA ramps from

handicapped parking and business entrances. Forms were placed and meets LS and ADA specs. Aggregate was at the correct depth and compacted. Mike was installing #4 epoxy bars into the curbing at the handicapped spots. He

will be using KCMMB mix and white cure.

_					
c	n	nn	20	ni	tc.