

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20173864	Date:	March 22, 2019
Project Title:	TPC INTERIORS	Applicant:	
Location:	1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081		ADVANTAGE FIRE PROTECTION SYSTEMS INC 404 B NW 11TH ST BLUE SPRINGS, MO 64015
Type of Work:			
Occupancy Group:	UC		
Description:	SHELL BUILDING FOR FUTURE OFFICE/WAREHOUSE	Primary:	(816) 224-3400
Construction Type:	Type IIB (Unprotected)		
Map Page:	195R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

All field tests and acceptance testing of the system is required to be completed prior to the buildings final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.