

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183262  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	John Borns	Partial	Friday, March 22, 2019

Partial Correction:

1	Misc	OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: LEFT WING COMPLETE; BUILDING DRAIN FROM LEFT WING S/SE TO NEAR EAST ELEVATOR; BRANCH PIPING AT CENTER SECTION; BUILDING DRAIN EXTENDED SE/E TO (AAK); BUILDING DRAIN EXTENDED E TO 5' O/S E B/L; BRANCH PIPING TO COMPLETE DWV AT RIGHT WING; <b>TWO SHORT RUNS OF PEX WATER PIPING AT EAST END OF RIGHT WING</b>
---	------	--

ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312

Partial Correction:

2	Misc	OK TO COVER WHEN READY UNDER-SLAB RADON PIPING AT: LEFT WING; <b>RIGHT WING</b>
---	------	---

Comments: