CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20180922 Address: 500 NE WENONGA PL, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, March 25, 2019
Corrective Action Required:			
	-FINAL GRADE, SOD, ROOF DRAINAGE AND SPLASHBLOCKS		
	-LOWER WATER METER TO FLUSH WITH FINAL GRADE		
	-SEAL EXTERIOR: PENETRATIONS, ABOVE METER AND AC DISCONNECTS,		
	LIGHTS, ETC		
	-COMPLETE DECK AND AC INSTALATION		
	-FASTEN WINDOW WELL LADDER		
	-PROVIDE ENGINEER DOCUMENT FOR GARAGE DOOR INSTALLATION. CHECK		
	DOOR BRACKET SUPPORTS		
	-INSTALL GARAGE DOOR SELF CLOSERS		
	-INSTALL LAUNDRY RECEPTACLE FLUSHED WITH WALL		
	-INSTALL SECURITY STRIKE PLATE FOR REAR EXTERIOR DOOR		
	-ONE BREAKER NOT LABELED		
	-MOVE WATER HEATER MIN 1" AWAY FROM WATER HEATER B-VENT		

Comments: