

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20184003
Address: 100 SW MEADOWBROOK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Wednesday, March 27, 2019

Corrective Action Required:

- | | | | |
|---|------|----|---|
| 1 | Misc | 1. | Add stud at girder truss north wall in garage. |
| | | 2. | Fire stop electrical wiring penetrations at bed 2 bath top plate. |
| | | 3. | Install stud shoe in basement bath |

OK TO INSULATE

Comments: