

Inspection Summary

Permit #: PRSITE20183647, Development - Site

PARAGON STAR

Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	John Jackson	Partial	Wednesday, March 27, 2019
Informational			
1	Contractor installed Approximately 60' of RCB PreCasted Concrete 8'X8' storm piping. Which includes 15 & 35 degree bends.		
DE - Storm - Material Verification	John Jackson	Passed	Wednesday, March 27, 2019
Informational			
1	All the materials appear to be correct.		
DE - Storm - Pipe	John Jackson	Partial	Wednesday, March 27, 2019
DE - Storm - Pipe	John Jackson	Partial	Wednesday, March 27, 2019
Informational			
1	Contractor had to reset RCB concrete due to incorrect sequencing of precast concrete storm line 300. Contractor appeared to have reestablish with stake center line. Last documented observation on project by inspector was 35 Degree bend @ Sta 1+54.93. John Jackson 03/27/2019 3:34 PM		

Comments:
