

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20182954  
Address: 4716 NE GATEWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, March 27, 2019

Corrective Action Required:

1 Misc

FRAMING:

-Provide city-approved plan on site

\*\*You have the red-stamped copy of the plan?

\*\*The city does not have a mean to copy the plan and give it to you. You should contact the permit technician about the missing plan

-Frame CS-PF walls per plan

\*\*see the plan detail please

\*\*the CSPF walls are not framed per plan. You must get your engineer involved

-Toe nail all joists to basement sill plates

\*\*not all joists are toe-naled to sill plates

\*\*look at the front foundation walls

\*\*DO NOT INSULATE BASEMENT SILL PLATES

Comments:

