



March 25, 2019

ABI Corporation

Re: 4517 SW Nautilus Place  
Creekside at Raintree Lake, Lot 13  
City permit #: 2018-0263

Apex Engineers, Inc. observed the pier holes for the proposed house located at the above referenced address. The pier holes were inspected on 3/25/19.

All the piers specified, including two (2) basement slab support and three (3) deck piers, were drilled up to 9'-0" to sandstone and in compliance with our report.

Our firm recommends approval of the drilled pier holes for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction.

#### LIMITATIONS

The above observations are based on on-site conditions at the time of our inspection and are in regards to pier installation and bearing verification only. These conditions may be altered over time and/or with changes in the weather of which could require further excavation and/or re-drilling to provide adequate support at the base of the piers. Therefore, if changes occur that could affect any of the recommendations given in the report, Apex Engineers, Inc. shall be called back and allowed to re-evaluate our previous recommendations and/or conclusions. If changes in the condition of the site occur and Apex Engineers, Inc. is not allowed the opportunity to re-evaluate the site to respond to any of these changes, our firm cannot be responsible for the effect of any of the conditions that differed from those reported herein.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,  
Apex Engineers, Inc.

  
Patrick Corrigan  
Engineering Technician

