

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20182892  
**Address:** 4419 SW AMETHYST DR, LEES SUMMIT, MO 64082  
**Inspected On:** Monday, April 01, 2019  
**Inspected By:** Mike Copeland  
**Expiration Date:** 5/31/2019 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Temporary C of O	Monday, April 01, 2019

**Corrective Action Required:**

1      Misc      Final grade, sod, splashblocks.

Water meter is below grade, must be flush with final grade.

Footing wasn't approved, two pads.