

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20184084
Address: 840 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Failed	Tuesday, April 02, 2019

Partial Correction:

1	Misc	OK TO COVER WHEN READY GWB CEILING / SOFFIT / BULKHEAD FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: HANGING BULKHEADS; FITTING AREA;
---	------	---

Corrective Action Required:

2	Misc	FLOOR AREA MULTIPLE HEADS NOT SECURED.
---	------	--

Comments: