

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20181397
Address: 1717 NE PARKWOOD DR, LEES SUMMIT, MO 64064
Inspected On: Tuesday, April 02, 2019
Inspected By: Mike Copeland
Expiration Date: 5/16/2019 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Temporary C of O	Tuesday, April 02, 2019

Corrective Action Required:

1	Misc	-Sidewalk not approved on record -Final grade, sod, splashblocks -Lag screw deck ledger board per code -Install two 1/2" through bolts at each deck beam connection to post -Deck cedar posts cannot be buried into soil
---	------	--