

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Wednesday, April 03, 2019

Partial Correction:

1	Misc	OK TO COVER WHEN READY UNDER-SLAB CONDUIT: FROM DATA/ELECTRICAL ROOM LOCATION WEST ONE 3/4" & ONE 1-1/4" UNDER PERIMETER FOOTING; FROM DATA/ELECTRICAL ROOM LOCATION THREE 3" TO 80' S/SE TOWARD CLUBHOUSE; WITHIN CLUBHOUSE TWO 4" PVC FROM ELECT/IT RM TO CT LOCATION + FOUR 3" FROM ELECT/IT RM W/NW TO CONNECT TO EARLIER INSPECTED; THREE 3" PVC FROM EAST IT/ELECT RM ~90' EAST TO SWEEPS AT RISER LOCATION NEAR A.AR; FEEDER CONDUIT FROM 101 TO 107; FLOOR BOX & CONDUIT AT E END OF RIGHT WING + CONDUIT AT ISLAND SAME LOCATION;
---	------	--

Partial Correction:

2	Misc	3/4" CONDDUIT FOR ISLAND AND ONE FLOOR BOX NE UNIT; DATA CONDUITS TO MECH ROOM APPROVED; FEEDER CONDUITS MECH ROOM TO 40 FEET SOUTH; UFER CONNECTIONS APPROVED;
---	------	---

Comments: