

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183710  
Address: 2320 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                            | Inspector: | Outcome: | Date:                     |
|--|------------|----------|---------------------------|
| <b>Footing Inspection - Commercial</b> | John Borns | Failed   | Wednesday, April 03, 2019 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | RE-BAR AT INTEGRAL COLUMN FOOTINGS NOT AT LENGTHS PER SHOP DRAWINGS.<br>3" MIN CLEARANCE PER ACI NOT PROVIDED AT TRENCH BOTTOMS AND BANKS. |
|---|------|--|

**Comments:**