

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182860
Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Wednesday, April 03, 2019

Partial Correction:

1	Misc	TWO SS GREASE DUCTS INSTALLED FROM HOOD TO ROOF. 1ST LAYER FIRE WRAP APPLIED TO NORTH DUCT -- OK TO APPLY 2ND LAYER.
---	------	--

Comments: