

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183800
Address: 4509 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Thursday, April 04, 2019

Corrective Action Required:

1	Misc	Provide engineers report on 2 joist that have been cut to accommodate plumbing in garage. Double lvl at heat flue is not being fully supported rework framing for full bearing. Strap top plates at heat flue fir out. In mudroom. Gas line is not connected to fireplace. No pressure at gas line gauge. Install sliding glass doors in basement Install double joist hangers at cantilever right of main elec panel in basement
---	------	---

Comments: