
Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision
MONTICELLO 3RD PLAT

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection Informational	John Jackson	Failed	Thursday, April 04, 2019

- 1 Some issues of immediate concern are on the East end (Saratoga Court) of project silt from Lots 99, 100 & 101 have caused Field Inlet 3-5 to be clogged with silt. Silt fencing along that very same street needs to be cleaned out and reinstalled. Found during Grading Inspection of site with Steven Conrick. Pictures of affected area will be available in CityView. John Jackson 04/04/2019 3:25 PM

Comments:
