

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183473
Address: 424 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Passed	Friday, April 05, 2019

RELEASE ELECTRICAL AND GAS SERVICES

Comments: OK TO COVER WHEN READY AFTER:

- PROTECT PVC PIPING AT LAUNDRY WITH TWO BOCA PLATES AND ONE SHIELD PLATE
- PROTECT ELECTRICAL WIRING WITH SHIELD PLATES AT: LEFT OF RANGE AND AT 2ND FLR SE ROOM STUD

AT FINAL INSPECTION ALL EXPOSED WORK IS SUBJECT TO APPROVAL INCLUDING BUT NOT LIMITED TO POST BASE PLATES AT BASEMENT AND FIREBLOCKING UNDER HYDROTUB.