

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170407
Address: 3560 SW HOLLYWOOD DR, Unit:6, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Partial	Monday, April 08, 2019

Corrective Action Required:

1	THIRD FLOOR	STRAP TOP PLATES AT PLUMBING VENT BORE IN PLATE TWO FAR NORTH UNTITS. OKAY TO INSULATE 3RD FLOOR ONLY
---	-------------	---

Comments: