

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20182959  
Address: 1309 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, April 10, 2019

Corrective Action Required:

1	Misc	-REMOVE ALL LOOSE SOIL AND GRAVEL FROM PIER HOLE. HOLES MUST BE DUG TO BEARING SOIL
---	------	---

**Comments:**