

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20181667  
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Sanitary Sewer - Vacuum</b>	John DiMauro	Partial	Wednesday, November 28, 2018

Informational:

1	Misc	John DiMauro 11/28/2018 10:08 AM
---	------	----------------------------------

The crew vacuum tested MH B-1  
The gauge held at 10 with no drop during the 2.5 min test. Test Passed.

**Comments:**