

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20181667
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	John DiMauro	Partial	Tuesday, November 27, 2018

Informational:

1

John DiMauro 11/27/2018 10:39 AM

Air pressure test for the sanitary sewer line G.

The test for the Line segment from station 6+27.21 to 7+77.05 is 149.84 LF.

Start PSI: 4

End PSI: 4

Test Time: 34 min 10 sec

Test passed

The test for the Line segment from station 2+27.21 to 6+27.21 is 400 LF.

Start PSI: 4

End PSI: 4

Test Time: 91 min 12 sec

Test passed

Comments: