

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183804
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water - Material Verification	Ronald Paynter	Partial	Thursday, April 11, 2019

Informational:

1 Misc

They are using pipe from Sanderson Pipe that meets C900 specs.

Informational:

2 Misc

Richards Construction is using American Flow Control gate valves. They are also using Megalug connectors.

Comments: