

Inspection Summary

Permit #: PRSUBD20181667, Development - Subdivision
Whispering Woods
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Detention Basin	John DiMauro	Partial	Thursday, April 11, 2019

Informational

1 John DiMauro 04/11/2019 10:29 AM

The Redford crew installed the riprap for the basin. The size, location and depth of the rip rap appears to match the approved plans. Photos are attached.

Comments: