

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20162865
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - ADA Inspection	John Jackson	Partial	Wednesday, April 03, 2019

Informational:

1

Met with contractor about % of ADA ramp along the collector street of Jamestown Dr. & Goshen Dr. NE corner. 5% on ramp is allowed because it is located on the collector street. Contractor was forming the other sidewalks for ADA ramps throughout the project.

Comments: