



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20183043	Date:	April 15, 2019
Project Title:	ARCADE ALLEY	Applicant:	
Location:	316 SE DOUGLAS ST, LEES SUMMIT, MO 64063	SECURITY ONE SERVICES INC PO BOX 1910 LEES SUMMIT, MO 64063	
Type of Work:			
Occupancy Group:	A-2		
Description:	TENANT FINISH FOR ARCADE WITH FULL SERVICE BAR AND SOME FOOD SERVICE	Primary: (816) 554-3333	

**invite planner to final to verify screening of rooftop
equipment

Construction Type: Type VB (Unprotected)
Map Page: 195G

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Acceptance testing of the fire alarm system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.