

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183844
Address: 108 SW MEADOWBROOK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Tuesday, April 16, 2019

Corrective Action Required:

- | | | | |
|---|------|----|--|
| 1 | Misc | 1. | Fire stop unused bore in laundry room top plate at garage wall. |
| | | 2. | Protect plumbing at top plate in laundry rm. |
| | | 3. | strap top plate in laundry where top plate is cut out for plumbing. |
| | | 4. | Secure fireplace. |
| | | 5. | Nail garage portal sheathing per code. |
| | | 6. | Only 2 psi showing on gas line pressure. |
| | | 7. | Sheathing around fireplace cantilever and to the left and right of cantilever should be continuous to the soffit. EXTERIOR |

Comments: