

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20183647  
Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Miscellaneous PWORKS Inspection</b>	John Jackson	Passed	Tuesday, April 16, 2019

Informational:	
1	Contractor excavated existing sanitary to encase in concrete as per plan.
Informational:	
2	Miscellaneous Correction
	Contractor poured concrete encased around Kansas City 24" SDR Sanitary. Storm sewer Line 700 shall cross above the existing at encasement of approximately 40'X6'

**Comments:**