

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183647
Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Miscellaneous PWORKS Inspection	John Jackson	Partial	Tuesday, April 16, 2019

Informational:		
1		Contractor excavated existing sanitary to encase in concrete as per plan.
Informational:		
2	Miscellaneous Correction	Contractor poured concrete encased around Kansas City 24" SDR Sanitary. Storm sewer Line 700 shall cross above the existing at encasement of approximately 40'X6'

Comments: