

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183647
Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection		Partial	Wednesday, April 10, 2019

Corrective Action Required:

1	Matting was installed along river banks North & South sides. Contractor was unable to restore silt fencing. I talked with Casey Williams (Senior Superintendent) of Fogel - Anderson Construction I reminded him of the urgency for the silt fence to be reinstalled fencing to protect against erosion into waterway. I will send a letter to stress that my expectation is that the fencing will be completely reinstalled by the close of business 4/11/19. John Jackson 04/10/2019 3:24 PM
---	--

Comments: