

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183647
Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	John Jackson	Partial	Monday, April 01, 2019

Informational:

1

Contractor has installed approximately 140' of 8'x8' RCB storm sewer pipeline. Contractor meet with Plan Engineer & manufacture and found that bends (15 & 35 degree bends) were off roughly 5 degrees overall. Plan Engineer determine that the tolerance was still acceptable. Contractor continued installing storm line after I left site at approximately 2:15 pm.
John Jackson 04/01/2019 3:55 PM

Comments: